



Purchasing Department

209 Water Street
Johnson City, TN 37601
(423) 975-2716

ADDENDUM

TO: All Prospective Vendors

FROM: Debbie Dillon,
Director of Purchasing

SUBJECT: Addendum No. 1 – ITB # **6046**
Sevier Street Culvert Improvement Project

DATE: July 26, 2016

Consider this addendum an integral part of the above referenced Invitation to Bid:

1. Description of the revision:

Questions and Answers:

- 1.1. Sheet 5 of 13; "New Fence" shown around the new retaining wall/end of culvert - Is this actually the Pedestrian Rail?
 - Yes, this is the pedestrian rail.
- 1.2. Sheet 5 of 13; "New Fence" shown along southern property line - Is this a chain link or aluminum as shown on sheet 9 of 13 (Fence Detail) - and is this part of bid? (Legend shows chain link).
 - The fence along the southern property line is the fence detail on sheet 9. This will be installed by the City. (Not part of the Bid)
- 1.3. Sheet 13 of 13; Is the Landscaping shown to be an item within 2100-1 on bid sheet or is this not a part of this bid?
 - Per the Pre Bid, this would be the location you would put the cost of the final stabilization for the project area.

2. Description of the revision:

Clarifications:

- 2.1. No landscaping (except soil stabilization, erosion control measures, and stream bank stabilization) will be part of the bid.
- 2.2. A grass seed specification can be found in the Bid Documents under Appendix A – Project Specifications - Section 02485 – Seeding.

NOTE: The attached Contractor's Envelope Form must be completed and placed on the outer most envelope or it will not be opened.

All other specifications remain the same. **Vendor to acknowledge receipt of this addendum by initialing and returning the addendum notice with the return bid package or via facsimile if it has already been submitted.** Your unopened response envelope can be returned to you for re-submittal upon request. Any questions regarding addendum submittal please contact this office.

Attachments:

1. Bid Envelope Form.

/dd



STATE CONTRACTORS LICENSING INFORMATION BID ENVELOPE FORM

THIS FORM MUST BE FIRMLY ATTACHED TO THE OUTSIDE OF THE ENVELOPE
CONTAINING THE BID. NO BID WILL BE CONSIDERED IF THIS FORM IS INCOMPLETE OR
NOT ATTACHED TO THE OUTERMOST BID ENVELOPE IF BID IS \$25,000+

PART 1

ALL BIDDERS MUST COMPLETE

| | |
|-----------------------------------|--|
| TO: | City of Johnson City, Tennessee ITB# 6046 - Sevier Street Culvert Improvement Project |
| DUE DATE & TIME: | JULY 28, 2016 2:00 PM |
| LOCATION: | OFFICE OF PURCHASING DIRECTOR, 209 WATER STREET JOHNSON CITY, TN 37601 |
| NAME OF BIDDER: | |
| ADDRESS OF BIDDER: | |
| FEDERAL ID # OF BIDDER: | |
| LICENSE NO.: | # |
| LICENSE CLASSIFICATION OF BIDDER: | |
| EXPIRATION DATE: | |
| MONETARY LIMITS: | |

PART 2

BIDDER MUST COMPLETE THIS SECTION IF BID INVOLVES: \$25,000+ (1) ELECTRICAL WORK,
(2) PLUMBING WORK, (3) HEATING, VENTILATION, AIR CONDITIONING, (4) GEOTHERMAL WORK
OR \$100,000+ (5) MASONRY.

IF NOT, ENTER NONE IN THE SPACES FOR ITEM (A) BELOW.

| (1) ELECTRICAL | (2) PLUMBING | (3) HVAC | (4) GEOTHERMAL | (5) MASONRY |
|---|---|--|---|--|
| A) Name of licensed Electrical contractor: | A) Name of licensed Plumbing contractor: | A) Name of licensed HVAC contractor: | A) Name of licensed Geothermal contractor: | A) Name of licensed Masonry contractor: |
| B) License #: | B) License #: | B) License #: | B) License #: | B) License #: |
| C) License Classification and Limits: | C) License Classification and Limits: | C) License Classification and Limits: | C) License Classification and Limits: | C) License Classification and Limits: |
| D) License expiration date: | D) License expiration date: | D) License expiration date: | D) License expiration date: | D) License expiration date: |