



Purchasing Department

209 Water Street
Johnson City, TN 37601
(423) 975-2716

ADDENDUM

TO: All Prospective Vendors

FROM: Debbie Dillon, 
Director of Purchasing

SUBJECT: Addendum No. 4 –ITB #6076
King Creek Basin

DATE: October 10, 2016

Consider this addendum an integral part of the above referenced Invitation to Bid:

See attached instructions on how to calculate for the AGT glowing sidewalk.

All other requirements remain the same. **Vendor shall acknowledge receipt of this addendum by initialing and returning the addendum notice with the return solicitation package or via e-mail if it has already been submitted.** Your un-opened response envelope can be returned to you for re-submittal upon request. Any questions regarding addendum submittal please contact this office or Jennifer Salyer at Barge, Waggoner, Sumner and Cannon, Inc.

/dd

ADDENDUM NO. 4

October 10, 2016

PROJECT: King Creek Basin

JOB NUMBER: 36057-01

OWNER: City of Johnson City

ARCHITECT: BARGE, WAGGONER, SUMNER & CANNON, INC.
4 SHERIDAN SQUARE, SUITE 100
KINGSPORT, TENNESSEE 37660

BID DATE: October 12, 2016 at 2:00 p.m.

ALL BIDS SHALL CONFORM TO THIS ADDENDUM:

The following items covering changes in the bidding requirements shall apply to and become a part of the requirements thereof.

Receipt of this Addendum shall be acknowledged by inserting this number and date in the space provided on the Bid Form. Failure to do so may result in disqualification of the Bidder. This addendum consists of 1 pages with the following attachments:

GENERAL

ITEM 1. To clarify the information provided in Item 6 on Addendum No. 3, the formula for calculating the aggregate quantities for the AGT glowing sidewalk shall be as follows.

Total SF of sidewalk × % of distribution ÷ application rate = lbs of aggregate

Example Calculations

1,000 SF × 50% ÷ 10 lbs = 50 lbs.

1,000 SF × 30% ÷ 10 lbs = 30 lbs.

1,000 SF × 20% ÷ 2 lbs = 4 lbs.

END OF ADDENDUM NO. 4